

## Product Introduction

Atmospheric pressure sensor adopts original imported sensors, stable measurement data, high precision, strong anti-interference ability, long service life, can accurately measure the value of atmospheric pressure, while the built-in temperature and humidity sensors, suitable for a variety of environments under the air pressure and temperature and humidity measurement.



## Use Case Scenarios

It is widely used in greenhouses, environmental protection, weather stations, ships, docks and other outdoor locations.

## Features

1. Designed for real-time monitoring of environmental temperature, humidity and air pressure.
2. Wall-mounted, easy to use.
3. Provides RS485 communication interface and DC5V power supply.

## Product Specifications

Specifications	
Model	UB-ATHP-N1
Power Supply	DC 5V
Max Current	139mA (@5V)
Measuring Range	Pressure: 26~126kPa Temperature: -40°C~80°C Humidity: 0~100%RH
Accuracy	Pressure: ±50Pa Temperature: ±0.2°C (@0~65°C) Humidity: ±2%RH (@10~90%RH)
Working Environment	-40~60°C, 0~80%RH
Connector	Audio
Communication Protocol	RS485 Modbus RTU Protocol
RS485 Address	0xCE
Baud Rate	1200 bit/s, 2400 bit/s, 4800 bit/s, 9600 bit/s (default), 19200 bit/s

## Wiring Instruction



## Communication protocols

### 1. Communication basic parameters

Communication Basic Parameter	
Coding System	8-bit binary
Data Bit	8 bits
Parity Checking Bit	none
Stop Bit	1 bit
Error Checking	CRC Check
Baud Rate	1200 bit/s, 2400 bit/s, 4800 bit/s, 9600 bit/s (default), 19200 bit/s

## 2. Data Frame Format

The Modbus-RTU communication protocol is used in the following format:

- Initial structure  $\geq 4$  bytes in time.
- Address code: 1 byte, default 0xCE.
- Function code: 1 byte, support function code 0x03 (read only) and 0x06 (read/write).
- Data area: N bytes, 16-bit data, high byte comes first.
- Error check: 16-bit CRC code.
- End structure  $\geq 4$  bytes of time.

Request							
Slave Address	Function Code	Register Address	No. of Registers	CRC LSB	CRC MSB		
1 byte	1 byte	2 bytes	2 bytes	1 byte	1 byte		
Response							
Slave Address	Function Code	No. of Bytes	Content 1	Content 1	...	Content n	CRC
1 byte	1 byte	1 byte	2 bytes	2 bytes	...	2 bytes	2 bytes

## 3. Register Address

Register Address				
Address (hex)	Content	Register Length	Function Code	Description of definitions
0x0000	Pressure	1	03	Unsigned integer data, divided by 10
0x0001	Temperature	1	03	Signed integer data, divided by 10
0x0002	Humidity	1	03	Unsigned integer data, divided by 10
0x0064	Address	1	03/06	1 ~ 255

### NOTE

1. Do not pull the sensor lead wire, do not drop or hit the sensor violently.
2. Do not place the transmitter directly under high temperature environment.
3. Prohibit the transmitter to be placed in steam, water mist, water curtain or condensation environment for a long time.